



City of Leander

**INVITATION FOR BID
FIRE STATION #2 ROOF REPLACEMENT
ADDENDUM**

IFB No. 14-004

Addendum #: 1

Date: December 16, 2013

Please note the clarification and/or additional information for the solicitation referenced above.

1. Q: Is a Bid Bond required?

A: No Bid Bond is required. However, upon award the successful Respondent will be required to furnish Payment and Performance Bonds to the City per Part III, #10 of the solicitation.

2. Q: Is the pavilion roof over the nearby mailboxes also to be replaced?

A: No.

3. Q: Is there a color requirement for the metal?

A: The Crystal Falls HOA requires an "earth-tone" roof with dull finish. Earth-tone colors are listed as rust, beige, gray, dark green, tan, brown, taupe, ecru, and other more neutral background colors.

4. Q: Does the City prefer a Standing Seam or Exposed Fastener system?

A: The City will evaluate each type system submitted provided it meets specification. Two submittals may be provided.

Approved by

Joy Simonton, Purchasing Agent

By the signatures affixed below, Addendum No. 1 is hereby incorporated into and made a part of the above referenced solicitation.

ACKNOWLEDGED

Vendor

Authorized Signature

Date

RETURN ONE COPY SIGNED COPY OF THIS ADDENDUM TO THE PURCHASING OFFICE WITH YOUR SEALED PROPOSAL. FAILURE TO DO SO MAY AUTOMATICALLY DISQUALIFY YOUR RESPONSE FROM CONSIDERATION FOR AWARD.